





NOTES:

- 1) REFER TO SECTION 15112 OF THE SPECIFICATIONS
- 2) INSTALL WARNING/IDENTIFICATION TAPE AS SHOWN ON WP-01
- 3) LOCATE BACKFLOW PREVENTION DEVICE (BPD) IN SUCH A MANNER THAT WILL ALLOW THE DEVICE TO BE READILY ACCESSIBLE FOR INSPECTION & REPAIR
- 4) ALL ABOVE GROUND PIPING, UNIONS, ELBOWS, & NIPPLES SHALL BE SOLDERED OR THREADED BRASS
- 5) NO CONNECTIONS OF ANY KIND WILL BE ALLOWED IN THIS AREA, INSPECTION BY THE DISTRICT SHALL TAKE PLACE PRIOR TO BACKFILL. INSTALL A CASING ENCASED IN CONCRETE WHEN THE DISTANCE BETWEEN THE METER BOX AND THE RISER TO THE BPD EXCEEDS 450mm (18'').
- 6) INSTALL AN ANGLE PRESSURE REDUCING VALVE IN LIEU OF THE FIRST 90° ELL WHEN SYSTEM PRESSURE EXCEEDS 1.03 MPa (150 PSI) OR WHEN RECOMMENDED BY THE BACKFLOW MANUFACTURER
- 7) TESTING SHALL BE CONDUCTED IN ACCORDANCE WITH SECTION 15112 OF THE SPECIFICATIONS PRIOR TO ACCEPTANCE BY THE DISTRICT
- 8) BPD & APPURTENANCES INSTALLED FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN SECTION 15151 OF THE SPECIFICATIONS
- 9) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST



LEGEND ON PLANS

ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
1	METER BOX & METER ASSEMBLY SEE WS-01 & WS-02	6	BRASS OR COPPER PIPE SEE NOTE 4
2	SCH 80 PVC, BRASS OR COPPER PIPE	7	75mm (3'') LONG NIPPLE SEE NOTE 4
3	CONCRETE THRUST BLOCK SEE WT-01	8	BALL VALVE "SHUT-OFF"
4	90° ELL SEE NOTES 4 & 6	9	REDUCED PRESSURE BACKFLOW DEVICE
5	CONCRETE SLAB, MINIMUM 100mm (4'') THICK x 450mm (18'') WIDE	10	ENCLOSURE (OPTIONAL)
		11	UNION SEE NOTE 4
		12	ANGLE PRV SEE NOTES 4 & 6

19mm THRU 50mm (3/4" THRU 2'') REDUCED
PRESSURE BACKFLOW PREVENTION DEVICE

WATER AGENCIES STANDARDS

COMMITTEE APPROVAL: 02/01/2008

DRAWING NUMBER: WR-01